



TECHNICKÝ SKÚŠOBNÝ ÚSTAV PIEŠŤANY, s.p.
Krajinská cesta 2929/9
821 01 Piešťany, Slovenská republika



SNAS
Reg. No. 00001011

EC - CERTIFICATE OF CONFORMITY 1299 - CPD - 0046

In compliance with the Directive 93/19/EEC of the Council of European Communities of 21 December 1993 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of Communities of 22 July 1993, it has been stated that the construction product:

Pillar fire hydrant, DN 100, PN 16
Type A, outlets 2xR
Type C, outlets 2xR or 2xH + 1xA.

is assigned for installing into outdoor water pipes for water supply intended for fire extinguishing including water assigned for human consumption, under condition, that used materials, including lubricants, coming into contact with water for human consumption shall comply with the National Regulations in the country of use.

placed on the marked by producer:

GRUP ROMET S.A., Brăilei Street, No.15, 120118 Buzău, Romania

and produced in the factory

SC ROMITEM SEL, Brăilei Street No.15, 120118 Buzău, Romania

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved body No. 1299 - Technicky skúšobny ústav Piešťany, s.p. - has performed the initial type-testing for the relevant characteristics of the products, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard

EN 14384: 2009

were applied and product fulfills all the prescribed requirements.

This certificate was first issued on November 2, 2010 and remains valid as long as the conditions laid down in the harmonized technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.



Piešťany, November 2, 2010

Ing. Anna ONDRAŠIČKOVÁ
Product Conformity Assessment Director

036409

Characteristic of construction product:

1. Operational reliability

- destruction - clauses: 4.2; 4.3; 4.4; 4.5*; 4.7; 4.11*; 4.14; 4.17*
- pressures - clause: 4.6
- direction of closure - clauses: 4.8
- number of opening turns - clause: 4.9
- resistance of hydrant to operating loads - clause: 4.10
- hydraulic characteristic - clause: 4.20

2. Connection dimensioning - clause: 4.12; 4.17*

3. Durability of operational reliability against corrosion - clause: 4.16

4. Durability of operational reliability; endurance - clause: 4.6.4

* Properties marked with asterisk shall be in conformity with regulatory requirements applicable in the country of product usage or their design is approved in the country of use.



Götz!